COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Variable Frequency Drive

MODEL DATA - FOR COMPRESSED AIR						
1	Manufacturer: ELGi					
	Model Number: OF275V-145	Date:	07-31-2024			
2	Air-cooled X Water-cooled	Type:	SCREW			
	Oil-injected X Oil-free	# of Stages:	2			
3	Full Load Operating Pressure b	145	psig ^b			
4	Drive Motor Nominal Rating	350	hp			
5	Drive Motor Nominal Efficiency	96.2	percent			
6	Fan Motor Nominal Rating (if applicable)	NIL	hp			
7	Fan Motor Nominal Efficiency	NA	percent			
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100cfm) ^d			
	276.10	1350	20.45			
	262.11	1271	20.61			
8*	248.33	1193	20.82			
	234.65	1114	21.06			
	221.18	1036	21.36			
	207.70	957	21.70			
9*	Total Package Input Power at Zero Flow ^{c,d} 0.00		kW			
	35.00					
	25.00					
10	20.00					
10	15.00					
	957 1036 1114 119	93 1271 1350)			
	Note: Graph is only a visual representation of the Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm incremer X-Axis Scale, 0 to 25% over maximum					

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Consumption	
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	+/- 10%
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.