COMPRESSOR DATA SHEET

Federal Uniform Test Method for Certain Air Compressors Not Applicable Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FOR COMP	PRESSED AIR		
1	Manufacturer: ELGi			
	Model Number: OF300V-145	Date:	07-31-2024	
2	Air-cooled X Water-cooled	Type:	SCREW	
	Oil-injected X Oil-free	# of Stages:	2	
3	Full Load Operating Pressure ^b	145	psig ^b	
4	Drive Motor Nominal Rating	400	hp	
5	Drive Motor Nominal Efficiency	96.2	percent	
6	Fan Motor Nominal Rating (if applicable)	NIL	hp	
7	Fan Motor Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100cfm) ^d	
	292.14	1438	20.32	
	271.98	1327	20.50	
8*	252.44	1216	20.75	
	233.21	1106	21.09	
	214.18	995	21.52	
	204.72	940	21.78	
9*	Total Package Input Power at Zero Flow ^{c,d} 0.00		kW	
10	35.00 30.00 25.00 20.00 15.00 940 995 1106 1 Note: Graph is only a visual representation or Note: Y-Axis Scale, 10 to 35, + 5kW/100acfm incre	ments if necessary above 35	8	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator. Consult CAGI website for a list of participants in the third party verification program: www.cagi.org

NOTES:

- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- $b. \ The \ operating \ pressure \ at \ which \ the \ Capacity \ (Item\ 8) \ and \ Electrical \ Consumption \ (Item\ 8) \ were \ measured \ for \ this \ data \ sheet.$
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%, manufacturer may state "not significant" or "0" on the test report.
- d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate		Volume Flow Rate	Specific Energy	No Load / Zero
at specified conditions			Consumption	Flow Power
m ³ / min	ft ³ /min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	+/- 10%
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	
1.5 to 15	53 to 529.7	+/- 5	+/- 6	
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 030.2

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data.