COMPRESSOR DATA SHEET



In Accordance With Federal Uniform Test Method for Certain Lubricated Air Compressors

Rotary Compressor: Variable Frequency Drive

	MODEL DATA - FO	OR COMPRESSED	AIR	
1	Manufacturer: ELGi			
	Model Number: EG 90SP 115 V		Date:	11/30/2023
2	X Air-cooled Water-cooled		Type:	SCREW
			# of Stages:	2
3*	Full Load Operating Pressure b	115	or suges.	psig ^b
4	Drive Motor Nominal Rating	125	hp	
5	Drive Motor Nominal Efficiency	95.4	percent	
6	Fan Motor Nominal Rating (if applicable)	2.1	hp	
7	Fan Motor Nominal Efficiency	NA	percent	
	Input Power (kW)	Capacity (acfm) ^{a,d}	Specific Power (kW/100 acfm) ^d	
	102.0	607.0	16.81	
	92.4	531.0	17.41	
8*	82.2	447.0	18.35	
	68.6	365.0	18.77	
	59.7	311.0	19.22	
	50.6	257.0	19.69	
9*	Total Package Input Power at Zero Flow c, d	0.00	kW	
10	Isentropic Efficiency	78.28	%	
11	O 125 25 10 10 125 25 10 10 125 25 10 10 10 125 25 10 10 10 125 25	Capacity(CFM) visual representation of the data in S	625	
	Note: Y-Axis Scale, 10 to 3		Section 8 sary above 35	

*For models that are tested in the CAGI Performance Verification Program, these items are verified by the third party administrator bisite for a list of participants in the third party verification program: www.cagi.org



- a. Measured at the discharge terminal point of the compressor package in accordance with ISO 1217, Annex E;
 ACFM is actual cubic feet per minute at inlet conditions.
- b. The operating pressure at which the Capacity (Item 8) and Electrical Consumption (Item 8) were measured for this data sheet.
- c. No Load Power. In accordance with ISO 1217, Annex E, if measurement of no load power equals less than 1%,
- manufacturer may state "not significant" or "0" on the test report. d. Tolerance is specified in ISO 1217, Annex E, as shown in table below:
 - NOTE: The terms "power" and "energy" are synonymous for purposes of this document.

Member

Volume Flow Rate at specified conditions		Volume Flow Rate	Specific Energy Volume Flow Rate Consumption	
m ³ / min	ft ³ / min	%	%	%
Below 0.5	Below 17.6	+/- 7	+/- 8	
0.5 to 1.5	17.6 to 53	+/- 6	+/- 7	1/ 100/
1.5 to 15	53 to 529.7	+/- 5	+/- 6	+/- 10%
Above 15	Above 529.7	+/- 4	+/- 5	

ROT 031.1

12/19 Rev 3 This form was developed by the Compressed Air and Gas Institute for the use of its members participating in the PVP. CAGI has not independently verified the reported data